

We thank you for your time spent taking this survey. Your response has been recorded.

Below is a summary of your responses

Download PDF

Purpose of utility survey:

This survey, in addition to other inputs, will be used to inform the utility's maturity level to establish a level for the current year (2021), as well as establish a target maturity for 2023.

The assessment of maturity will also leverage each utility's WMP submission, other supporting documents and disclosures, and select audits of relevant inputs where deemed necessary.

Instructions for answering each of the survey questions:

Utilities shall answer survey questions by:

- 1. Indicating the most appropriate response option to each question based on the <u>presently employed practices and capabilities</u> of the utility.
- Indicating the most appropriate response to each question for the utility's expected capabilities in 3 years (Q1, 2023) based on expected growth in maturity over the 3 year period of the Wildfire Mitigation Plan (WMP) to inform the utility's 3-year target maturity.

Only one response option should be selected unless the question is specified as

select all that apply.

Importantly, utilities shall only indicate that they meet a given response option if they meet <u>all</u> of the characteristics described within that response option, across <u>all</u> <u>instances</u> where that question is valid.

For example, if a utility meets all criteria for answer ii of a given question and all but one criterion for answer iii, that utility must select answer ii. Similarly, if a utility meets all criteria for answer ii of a given question over 60% of its territory but meets all criteria for answer i over 100% of its territory, the utility must select answer i.

Instructions for use of the electronic survey:

Please fill out the electronic survey in its entirety.

The unique link provided to you can be used on multiple devices. Please only use on a single device at a time. To avoid creation of any conflict copies, please allow 15 minutes to pass before switching between devices. For example, if passing the survey off to a colleague on a different machine please have the colleague wait for 15 minutes after you stop working to begin.

If you are completing the survey in multiple sittings, your progress will be saved. You may use the unique link provided to you to resume where you left off.

Confirmation of survey responses:

Within 24 hours of completing and submitting the survey in its entirety, the main utility contact designated below will receive a PDF of your responses for final verification by email. Please review that document, confirm all of your responses one final time, and provide your signature as instructed in the PDF.

Your responses will be evaluated by the CPUC following this final verification.

A. Risk mapping and simulation

A.I Climate scenario modeling and sensitivities Capability 1

A.I.a How sophisticated is utility's ability to estimate the risk of weather scenarios?

<u>Clarification</u>: Determining wildfire risk requires the utility to understand the probability of ignition and the consequences of such an ignition while taking various conditions into account (e.g., weather, fuel levels, etc.). Categorizing level of risk requires a set of calculations and judgements to group areas by wildfire risk level whereas quantitatively estimating risk refers to accurately quantifying risk on a continuous spectrum based on a host of wildfire risk drivers (e.g., as a function of ignition probability, propagation scenarios, and communities located in the propagation path).

	i. No clear ability to understand incremental risk under various weather scenarios	ii. Wildfire risk can be reliably determined based on weather and its impacts	iii. Weather scenarios can be reliably categorized by level of risk	iv. Risk for various weather scenarios can be reliably estimated	v. Incremental risk of foreseeable weather scenarios can be accurately and quantitatively estimated
Current Year		• • •	• O	• • •	· O
by Start of 2023	· O		0	0	· O

A.I.b How are scenarios assessed?

<u>Clarification</u>: Per the instructions, please only indicate that you meet a given response option if<u>you</u> <u>meet all the characteristics described within that response option</u>). So, hypothetically, if you do support your scenarios assessment by historical data of incidents and near misses and conduct internal assessments, but don't have an independent expert assessment, you would select (ii).



A.I.c How granular is utility's ability to model scenarios?



A.I.d How automated is the tool?

<u>Clarification</u>: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4



A.I.e What additional information is used to estimate model weather scenarios and their risk?



A.I.f To what extent is future change in climate taken into account for future risk estimation?



A.II Ignition risk estimation Capability 2

A.II.a How is ignition risk calculated?



A.II.b How automated is the ignition risk calculation tool?

<u>Clarification</u>: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4



Current Year	*		-		
by Start of 2023				,	

A.II.e What confidence interval, in percent, does the utility use in its wildfire risk assessments?

>60%, or no quantified



A.III Estimation of wildfire consequences for communities

Capability 3

A.III.a How is estimated consequence of ignition relayed?

	i. No translation of ignition risk estimates to potential consequences for communities	ii. Ignition events categorized as low or high risk to communities	iii. Ignition events categorized with 5 or more levels of risk to communities	iv. Consequence of ignition events quantitatively, accurately, and precisely estimated
Current Year	• O	· O	· O	
by Start of 2023	0	0	0	

A.III.b What metrics are used to estimate the consequence of ignition risk?



A.III.c Is the ignition risk impact analysis available for all seasons?

	i. No		ii. Yes
Current Year	0		
by Start of 2023	0	÷	

A.III.d How automated is the ignition risk estimation process?

<u>Clarification</u>: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4

	i. Not automated	ii. Partially (<50%)	iii. Mostly (≥ 50%)	iv. Fully
Current Year		0	0	0
by Start of 2023	· O		0	0

A.III.e How granular is the ignition risk estimation process?



A.III.f How are the outputs of the ignition risk impact assessment tool evaluated?



A.III.g How other inputs are used to estimate impact?



A.IV Estimation of wildfire and PSPS risk-reduction impact

Capability 4

A.IV.a How is risk reduction impact estimated?

i. No clear estimation of risk reduction

ii. Approach accurately reliably estimates estimates risk reduction potential of

iii. Approach risk reduction potential of

iv. Approach reliably estimates risk reduction potential of initiatives on an

v. Approach reliably estimates risk reduction potential of initiatives on an interval scale (e.g. specific quantitative units)



A.IV.b How automated is your ignition risk reduction impact assessment tool?

<u>Clarification</u>: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4

	i. N	Not automated	ii. Partially (<50%)	iii. Mostly (≥50%)		iv. Fully
Current Year			0	0	э	0
by Start of 2023		0		0	,	0

A.IV.c How granular is the ignition risk reduction impact assessment tool?

	i. Less granular than regional, or no tool at all	ii. Regional	iii. Circuit- based	iv. Span-based	v. Asset-based
Current Year	· O ·	0	· •	• O	· O
by Start of 2023	· O ·	0		• • •	• • •

A.IV.d How are ignition risk reduction impact assessment tool estimates assessed?

	i. No or limited formal evidence or support for estimates	ii. With evidence and logical reasoning	iii. Independent expert assessment	iv. Independent expert assessment, supported by historical data of incidents and near misses
Current Year	· O		· O	· • • •
by Start of 2023	· O	0	· •	0

A.IV.e What additional information is used to estimate risk reduction impact?

ha

		v. Existing
		and condition
		including
	iv. Existing	operating
	hardware type	history; level
	and condition,	and condition
iii. Existing	including	of vegetation;
ardware type	operating	weather; and

	i. None	ii. Existing hardware type and condition	and condition, including operating history	history; level and condition of vegetation; weather	combination Rarititiatikyse ancelogadiyon, cleployed
Current Year	· O	· O	• O	iv. Existing	operating
by Start of 2023	0	0	iii. Existing	and condition, including	and condition of vegetation;

A.V Risk maps and simulation algorithms Capability 5

<u>Clarification on terminology</u>: A risk map is a collection of data sufficient to represent the spatial distribution (e.g., across a geography) of a given type of risk (i.e., the probability of an event and its consequence) and the spatial representation thereof. Risk maps may include maps of the probability of ignition along the utility's grid and may represent the consequences given ignition at various points along the grid. Risk maps may also combine these factors to show a weighted probability and consequence risk level across the utility's grid. Data inputs should include the variables and conditions used to calculate risk for a given point, line, or polygon. The risk mapping algorithm is a methodology or formula for interpreting a risk calculation from these data inputs.

A.V.a What is the protocol to update risk mapping algorithms?



A.V.b How automated is the mechanism to determine whether to update algorithms based on deviations?

<u>Clarification</u>: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4

	i. N	Not automatec	ł	ii. Partially (<50%)		iii. Mostly (≥50%)		iv. Fully
Current Year		0			-	0		0
by Start of 2023		0				0	,	0

A.V.c How are deviations from risk model to ignitions and propagation detected?

i. Not currently		iii. Semi-automated	iv. Fully automated
calculated	ii. Manually	process	process



A.V.d How are decisions to update algorithms evaluated?

	i. Not currently evaluated	ii. Independently evaluated by experts	evaluated by experts and historical data
Current Year	• •		· • • •
by Start of 2023	• O	. O	

iii Indonondontly

A.V.e What other data is used to make decisions on whether to update algorithms?



B. Situational awareness and forecasting

B.I Weather variables collected

Capability 6

B.I.a What weather data is currently collected?



B.I.b How are measurements validated?



B.I.c Are elements that cannot be reliably measured in real time being predicted (e.g., fuel moisture content)?

		i. No		ii. Yes
Current Year		0		
by Start of 2023	,	0	*	

B.I.d How many sources are being used to provide data on weather metrics being collected?

	i. None		ii. One		iii. More than one
Current Year	0	a:	0		
by Start of 2023	0	(m.)	0	÷	

B.II Weather data resolution

Capability 7

B.II.a How granular is the weather data that is collected?



	i. Less					
	frequently than	ii. At least	iii. At least four	iv. At least six	v. At least sixty	
	hourly	hourly	times per hour	times per hour	times per hour	
140 X 141 X	•	•				



B.II.c How granular is the tool?

	i. Less granular than regional, or no tool at all	ii. Regional	iii. Circuit- based	iv. Span-based	v. Asset-based
Current Year	· O ·		0	· O	· O
by Start of 2023	· O ·	0		• •	· O

B.II.d How automated is the process to measure weather conditions?

<u>Clarification</u>: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4

	i. Not automated	ii. Partially (<50%)	iii. Mostly (≥50%)		iv. Fully
Current Year	• •	0	0		
by Start of 2023	· O	0	0	2	

B.III Weather forecasting ability Capability 8

B.III.a How sophisticated is the utility's weather forecasting ability?



B.III.c At what level of granularity can forecasts be prepared?



B.III.d How are results error-checked?

		i. Results are not error checked		ii. Results are error checked against historical weather patterns	 iii. Criteria for option (ii) met, and forecasted results are subsequently error checked against measured weather data
Current Year	3	0		0	
by Start of 2023		0	÷	0	

B.III.e How automated is the forecast process?

Clarification: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4

	i. N	Not automated		ii. Partially (<50%)	iii. Mostly (≥50%)	iv. Fully
Current Year	,	0		0		0
by Start of 2023	-	0	·	0		0

B.IV External sources used in weather forecasting Capability 9

B.IV.a What source does the utility use for weather data?



B.IV.b How is weather station data checked for errors?



B.IV.c For what is weather data used?



B.V Wildfire detection processes and capabilities *Capability 10*

B.V.a Are there well-defined procedures for detecting ignitions along the grid?



B.V.b What equipment is used to detect ignitions?

i. No consistent set of equipment for detecting

ii. Well-defined equipment for detecting ignitions iii. Well-defined equipment for detecting ignitions along grid, **including remote detection equipment** iv. Well-defined equipment for detecting ignitions along grid, including remote detection equipment including cameras, and satellite



B.V.c How is information on detected ignitions reported?



B.V.d What role does ignition detection software play in wildfire detection?



C. Grid design and system hardening

<u>Clarification</u>: 'Hardening' refers to grid hardening as defined in the WMP guidelines: Actions (such as equipment upgrades, maintenance, and planning for more resilient infrastructure) taken in response to the risk of undesirable events (such as outages) or undesirable conditions of the electrical system in order to reduce or mitigate those events and conditions, informed by an assessment of the relevant risk drivers or factors.

C.I Approach to prioritizing initiatives across territory





C.II Grid design for minimizing ignition risk Capability 12

C.II.a Does grid design meet minimum G095 requirements and loading standards in HFTD areas?

					iii. Grid topology exceeds design requirements, designed based on accurate understanding of drivers of utility ignition
		i. No		ii. Yes	risk
Current Year	*	0	340		· O
by Start of 2023		0	ай. -	0	•

C.II.b Does the utility provide micro grids or islanding where traditional grid infrastructure is impracticable and wildfire risk is high?

gita initiasti acture is inipracticable and whathe fisk is high :

	i. No		ii. Yes
Current Year	0	×	
by Start of 2023	0		

C.II.c Does routing of new portions of the grid take wildfire risk into account?

		i. Yes	ii. No
Current Year	,		0
by Start of 2023	,		0

C.II.d Are efforts made to incorporate the latest asset management strategies and new technologies into grid topology?

		ii. Ye	es, some effort made	iii. Y	es, across the entire
	i. No		in HFTD areas		service area
Current Year	0	κ.		·	0
by Start of 2023	0		0		

C.III Grid design for resiliency and minimizing PSPS *Capability 13*

C.III.a What level of redundancy does the utility's transmission architecture have?



C.III.b What level of redundancy does the utility's distribution architecture have?

	i. Many single points of failure	ii. n-1 redundancy covering at least 50% of customers in HFTD	iii. n-1 redundancy covering at least 70% of customers in HFTD	iv. n-1 redundancy covering at least 85% of customers in HFTD
Current Year		· O	· O	O
by Start of 2023		0	· O	0

C.III.c What level of sectionalization does the utility's distribution architecture have?

iii. Switches in	iv. Switches in	
HFTD areas to	HFTD areas to	v. Switches in
individuallv	individuallv	HFTD areas to

	i. Many single points of failure	ii. Switches in HFTD areas to individually is Switches its	IF Strate Fred the HEURD the 1990 IN A Contract of the IN A Contract of the IN A Contract of the IN A Contract of the International of	isolation free that within the switch	individually is of the set of the Hand the set of the more that if of isolate consults, swith than fo more which 200
Current Year	i. Many single	HFTD areas to	 customers sit within one 	 customers sit within one 	 customers sit within one
by Start of 2023	failure	isolate circuits	svitch	svitch	switch

C.III.d How does the utility consider egress points in its grid topology?



C.IV Risk-based grid hardening and cost efficiency Capability 14

C.IV.a Does the utility have an understanding of the risk spend efficiency of hardening initiatives?

Clarification: 'Hardening initiatives' refers to all initiatives implemented by utility or by other utilities in

California



C.IV.b At what level can estimates be prepared?

i. Less granular	

	i. Less granular than regional.	ii. Regional	iii. Circuit- based iii. Circuit-	iv. Span-based	v. Asset-based
Current Year	or not at all	ii. Regonal	based	iv. Spanbased	v. Assebbased
by Start of 2023	· O ·	0		• • •	· O

C.IV.c How frequently are estimates updated?

	i. Never	i	i. Less frequently than annually	iii. Annually or more frequently
Current Year	0			0
by Start of 2023	0		0	

C.IV.d What grid hardening initiatives does the utility include within its evaluation?

Clarification: 'All Hardening initiatives' refers to all initiatives implemented by utility or by other

utilities in California

	i. None	ii. Some	iii. Most		iv. All	v. All, supported by independent testing
Current Year	0		0		0	· O
by Start of 2023	0	0		,	0	· O

C.IV.e Can the utility evaluate risk reduction synergies from combination of various initiatives?



C.V Grid design and asset innovation *Capability 15*

C.V.a How are new hardening solution initiatives evaluated?



Current Year



0

0

C.V.b Are results of pilot and commercial deployments, including project performance, project cost, geography, climate, vegetation etc. shared in sufficient detail to inform decision making at other utilities?



		i. No	ii. Yes
Current Year			0
by Start of 2023	,		0

D. Asset management and inspections

D.I Asset inventory and condition assessments Capability 16

D.I.a What information is captured in the equipment inventory database?

	i. There is no service territory- wide inventory of electric lines and equipment including their state of wear or	ii. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected	iii. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle, including records of all inspections	iv. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle, including records of all inspections and repairs and up-to- date work plans on expected future repairs and	v. There is an accurate inventory of equipment that may contribute to wildfire risk, including age, state of wear, and expected lifecycle, including records of all inspections and repairs and up-to-date work plans on expected future repairs and replacements wherein repairs and sensor outputs are independently
	disrepair	lifecycle	and repairs	replacements	audited
Current Year	• • •		0	• O	· O
Start of 2023	0	0		0	• O

D.I.b How frequently is the condition assessment updated?

	i. Never		ii. Annually	iii. Quarterly		iv. Monthly		v. Hourly
Current Year	0	·		0	2	0		0
Start of 2023	0	-		0	,	0	,	0

D.I.c Does all equipment in HFTD areas have the ability to detect and respond to malfunctions?

	i. No system and approach are in place to detect or respond to malfunctions	ii. A system and approach are in place to reliably detect incipient malfunctions likely to cause ignition	iii. Sensorized, continuous monitoring equipment is in place to determine the state of equipment and reliably detect incipient malfunctions likely to cause ignition	iv. Sensorized, continuous monitoring equipment is in place to determine the state of equipment and reliably detect incipient malfunctions likely to cause ignition, with the ability to de-activate electric lines and equipment exhibiting such failure
Current Year	· O		0	O
by Start of 2023	. O		. O	0

D.I.d How granular is the inventory?

	i. There is no inventory	ii. At the span level	i	iii. At the asset level
Current Year	· O	· O		
by Start of 2023	· O	O	2	

D.II Asset inspection cycle Capability 17

D.II.a How frequent are your patrol inspections?



D.II.b How are patrol inspections scheduled?

iii. Risk, as determined by iv. Risk, independently determined by





D.II.f What are the inputs to scheduling detailed inspections?

	i. At least annually updated or verified static maps of equipment and environment	ii. Predictive modeling of equipment failure probability and risk	iii. Predictive modeling supplemented with continuous monitoring by sensors	iv. Outdated static maps
Current Year		0	· O	• O
by Start of 2023	•	O	0	0

D.II.g How frequent are your other inspections?



D.III.a What items are captured within inspection procedures and checklists?



D.III.b How are procedures and checklists determined?



D.III.c At what level of granularity are the depth of checklists, training, and procedures customized?



D.IV Asset maintenance and repair Capability 19

D.IV.a What level are electrical lines and equipment maintained at?



D.IV.c What do maintenance and repair procedures take into account?



D.V.b Do contractors follow the same processes and standards as utility's own employees?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

D.V.c How frequently is QA/QC information used to identify deficiencies in quality of work performance and inspections performance?

	iii. On an ad						
	i. Never	ii. Sporadically	hoc basis	iv. Regularly	v. Real-time		
Current Year	0	0	0		· O		
by Start of 2023	0	• O	0		• •		

D.V.d How is work and inspections that do not meet utility-prescribed standards remediated?

	i. Lack of effective remediation for ineffective inspections or low- quality work	ii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections	iii. QA/QC information is used to identify systemic deficiencies in quality of work and inspections and recommend training based on weaknesses	iv. QA/QC information is used to identify systemic deficiencies in quality of work and inspections, grade individuals, and recommend specific pre-made and tested training based on weaknesses
Current Year	• • •		• • •	· O
by Start of 2023	• O	0		0

D.V.e Are workforce management software tools used to manage and confirm work completed by subcontractors?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

E. Vegetation management and inspections

E.I Vegetation inventory and condition assessments Capability 21

E.I.a What information is captured in the inventory?

v. Centralized inventory of vegetation clearances, including individual vegetation species and iv. Centralized their expected inventory of growth rate, as vegetation well as i. There is no iii. Centralized clearances, individual high vegetation inventory of including risk-trees individual inventory vegetation across grid. sufficient to clearances, vegetation Includes updetermine ii. Centralized including species and to-date tree vegetation inventory of predominant their expected health and clearances vegetation vegetation growth rate, moisture across the grid clearances species and as well as content to at the time of based on most individual individual high determine risk the last recent high risk-trees risk-trees of ignition and inspection inspection across grid across grid propagation O Ο 0 O **Current Year**



E.I.b How frequently is the inventory updated?

	i. Ne	ever	ii. Annually	iii ı y c	. Within 1 month of collection	iv. Wi wee collee	thin 1 k of ction	v. Within 1 of collect	day ion
Current Year	Ċ) .			0	· C)	· O	
by Start of 2023	· C) .	0			· C)	· O	

E.I.c Are inspections independently verified by third party experts?

	i. No		ii. Yes
Current Year	0	w.	
by Start of 2023	0	<i>3</i> .	

E.I.d How granular is the inventory?

		i. Regional		ii. Circuit-based		iii. Span-based		iv. Asset-based
Current Year	·	0		0		0	,	
by Start of 2023	,	0	×	0	e,	0		

E.II Vegetation inspection cycle Capability 22



E.II.c What are the inputs to scheduling vegetation inspections?

	i. At least annually- updated static maps of vegetation and environment	ii. Up to date, static maps of vegetation and environment, as well as data on annual growing conditions	iii. Predictive modeling of vegetation growth	iv. Predictive modeling of vegetation growth supplemented with continuous monitoring by sensors	v. Predictive modeling of vegetation growth supplemented with continuous monitoring by sensors and considering tree health and other vegetation risk factors for more frequent inspections in less healthy areas
Current Year		• O	0	· O	· O
by Start of 2023		0	0	0	O

E.III Vegetation inspection effectiveness Capability 23

E.III.a What items are captured within inspection procedures and checklists?



E.III.c At what level of granularity are the depth of checklists, training, and procedures customized?

0

	i. Across the service territory	ii. Across a region	iii. At the circuit level	iv. At the span level	v. At the asset level
Current Year		• O	• • •	· O	0
by Start of 2023		0	0	0	0

E.IV Vegetation grow-in mitigation Capability 24

E.IV.a How does utility clearance around lines and equipment perform relative to expected standards?

	i. Utility often fails to maintain minimum statutory and regulatory clearances around all lines and equipment	ii. Utility meet minimum statutory and regulatory clearances around all lines and equipment	iii. Utility exceeds minimum statutory and regulatory clearances around all lines and equipment
Current Year	· O		• O
by Start of 2023	• O		• O

E.IV.b Does utility meet or exceed minimum statutory or regulatory clearances during all seasons?

	i. No		ii. Yes
Current Year	0		
by Start of 2023	0	•	

E.IV.c What modeling is used to guide clearances around lines and equipment?

	i. Ignition risk modeling	ii. Ignition and propagation risk modeling		iii. None of the above
Current Year	• O	• O	2	
by Start of 2023	O	0		

E.IV.d What biological modeling is used to guide clearances around lines and equipment?

i. Species growth rates and species limb failure rates ii. Species growth rates and species limb failure rates, cross referenced with local climatological conditions

iii. None of the above

iv. Based on

predictive modeling

0

Current Yearii. Species growth rates
and species limb failureby Start of 2023i. Species growth rates
and species limb failureiii. Species growth rates
and species limb failureiii. Species growth rates
rates, cross referenced
with local climatological

E.IV.e Are community organizations engaged in setting local clearances and protocols?

	i. No	ii. Yes
Current Year		0
by Start of 2023		0

E.IV.f Does the utility remove vegetation waste along its right of way across the entire grid?

	i. No	ii. Yes
Current Year		0
by Start of 2023		0

E.IV.g How long after cutting vegetation does the utility remove vegetation waste along right of way?

		ii. Longer than 1	iii. Within 1 week or	iv. On the same
	i. Not at all	week	less	day
Current Year	· O		0	0
by Start of 2023	· O		• O	0

E.IV.h Does the utility work with local landowners to provide a costeffective use for cutting vegetation?

	i. No		ii. Yes
Current Year	•		0
by Start of 2023		-	0

E.IV.i Does the utility work with partners to identify new cost-effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste?

	i. No		ii. Yes
Current Year	0	×	
by Start of 2023	0		

E.V Vegetation fall-in mitigation *Capability 25*

E.V.a Does the utility have a process for treating vegetation outside of

	i. Utility does not remove vegetation outside of right of way	ii. Utility removes some vegetation outside of right of ways	iii. Utility systematically removes vegetation outside of right of way	systematically removes vegetation outside of right of way, informing relevant communities of removal
Current Year	· O	0		O
by Start of 2023	• O	0	0	

iv. Utility

E.V.b How is potential vegetation that may pose a threat identified?

	i. No specific process in place to systematically identify trees likely to pose a risk	ii. Based on the height of trees with potential to make contact with electric lines and equipment	iii. Based on the probability and consequences of impact on electric lines and equipment as determined by risk modeling	iv. Based on the probability and consequences of impact on electric lines and equipment as determined by risk modeling, as well as regular and accurate systematic inspections for high-risk trees outside the right of way or environmental and climatological conditions contributing to increased risk
Current Year	· O		· O	· O
by Start of 2023	0		0	0

E.V.c Is vegetation removed with cooperation from the community?

		i. No	ii. Yes
Current Year	*	0	
by Start of 2023		0	

E.V.d Does the utility remove vegetation waste outside its right of way across the entire grid?

		i. No		ii. Yes
Current Year	3		286	0
by Start of 2023			•	0

E.V.e How long after cutting vegetation does the utility remove vegetation waste outside its right of way?

	i. Not at all		ii. Lon 🖗 🥙 Khan 1	iii.	Withile Sweek or	iv. On the same
Current Year	i. Notat all		week		aege	dev
by Start of 2023	0	,			0	0

E.V.f Does the utility work with local landowners to provide a costeffective use for cutting vegetation?

	i. No	ii. Yes
Current Year		0
by Start of 2023		0

E.V.g Does the utility work with partners to identify new cost-effective uses for vegetation, taking into consideration environmental impacts and emissions of vegetation waste?

	i. No		ii. Yes
Current Year	0	ж.	
by Start of 2023	0		

E.VI QA/QC for vegetation maintenance Capability 26

E.VI.a How is contractor and employee activity audited?

			iii. Through an	
			established and	iv. Through an
			demonstrably	established and
			functioning audit	demonstrably
			process to manage	functioning audit
			and confirm work	process to manage
			completed by	and confirm work
			subcontractors,	completed by
			where contractor	subcontractors,
			activity is subject	where contractor
			automated audits	activity is subject to
	i. Lack of controls for auditing work completed, including inspections, for	ii. Through an established and functioning audit process to manage and confirm work	technologies capable of sampling the contractor's work (e.g., LiDAR scans,	technologies capable of sampling the contractor's work (e.g., LiDAR scans,
	employees or subcontractors	completed by subcontractors	photographic evidence)	photographic evidence)
Current Year	· O		0	0
by Start of 2023	0	· · · · · · · · · · · · · · · · · · ·	0	0
	•			

E.VI.b Do contractors follow the same processes and standards as utility's own employees?

Current Year	i. N o	ř.	ii. <mark>Ye</mark> s
by Start of 2023	0	<u>i</u>	

E.VI.c How frequently is QA/QC information used to identify deficiencies in quality of work performance and inspections performance?

		i. Never	ii. Sporadically	hoc basis	iv. Regularly	v. Real-time
Current Year	;	0	· O ·	0		· O
by Start of 2023		0	· O ·	0		· O

E.VI.d How is work and inspections that do not meet utility-prescribed standards remediated?



E.VI.e Are workforce management software tools used to manage and confirm work completed by subcontractors?

	i. No		ii. Yes
Current Year			0
by Start of 2023	0	τ.	

F. Grid operations and protocols

F.I Protective equipment and device settings Capability 27

F.I.a How are grid elements adjusted during high threat weather conditions?

i. Utility **does not** make changes to

ii Utility increases

iii. Utility increases sensitivity of risk reduction elements iv. Utility increases sensitivity of risk reduction elements during high threat weather

	adjustable	sensitivity of risk	during high threat	iv.old/dilttørisc basee ls
	equipment in	reduction	weather	sens ötiv i tisk frisk
	response to high	elements during	iii.c oltiliity iom sraass es	rec haatpopineg eamethts
	i. Whilibility el cherse anto t	high threat weather	sterostificitys of east	durriogitoigshrtbærat
	makceo o blaioges to	ii. Utdobyo dinticmesa se s	reduc tiois ses ments	wreiasteesr
Current Year	adjustable equipment in	sensitivity of risk reduction	during high threat weather	. conditions based on risk
by Start of 2023	response to high wildfire threat	elements during high threat weather	conditions and monitors near	mapping and monitors near

F.I.b Is there an automated process for adjusting sensitivity of grid elements and evaluating effectiveness?

<u>Clarification</u>: For clarification on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3 or 4

		ii. Partially automated		iii. Fully automated
	i. No automated process	process		process
Current Year	· O			0
by Start of 2023	• O		•	0

F.I.c Is there a predetermined protocol driven by fire conditions for adjusting sensitivity of grid elements?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

F.II Incorporating ignition risk factors in grid control Capability 28

F.II.a Does the utility have a clearly explained process for determining whether to operate the grid beyond current or voltage designs?

	i. No		ii. Yes
Current Year	0	*	
by Start of 2023	0		

F.II.b Does the utility have systems in place to automatically track operation history including current, loads, and voltage throughout the grid at the circuit level?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

F.II.c Does the utility use predictive modeling to estimate the expected

life and make equipment maintenance, rebuild, or replacement decisions based on grid operating history, and is that model reviewed?



F.II.d When does the utility operate the grid above rated voltage and current load?

	II. Only in conditions that are unlikely to cause					
	i. During any conditions		s wildfire		iii. Never	
Current Year	,			0		0
by Start of 2023			•	0	4	0

F.III PSPS op. model and consequence mitigation *Capability 29*

F.III.a How effective is PSPS event forecasting?



F.III.b What share of customers are communicated to regarding forecasted PSPS events?

	i. Affected customers are poorly communicated to , with a significant portion not communicated to at all	 ii. PSPS event are communicated to >95% of affected customers and >99% of medical baseline customers in advance of PSPS action 	 iii. PSPS event are communicated to >98% of affected customers and >99.5% of medical baseline customers in advance of PSPS action 	iv. PSPS event are communicated to >99% of affected customers and >99.9% of medical baseline customers in advance of PSPS action
Current Year	· O	· O	· O	
by Start of 2023	· O	· O	0	



	i. More than 1 hour	ii. Less than 1 hour	iii. Less than 0.5 hours	iv. Less than 0.25 hours	v. Less than 0.1 hours
Current Year	• • •	0	· O	0	
by Start of 2023	· O	· O	· O	· O	

F.III.f Are specific resources provided to customers to alleviate the impact of the power shutoff (e.g., providing backup generators, supplies, batteries, etc.)?

		i. No	ii. Yes
Current Year		0	
by Start of 2023	*	0	

F.IV Protocols for PSPS invitation

Capability 30

F.IV.a Does the utility have explicit thresholds for activating a PSPS?

iii. Utility has explicit policies and explanation for the thresholds above which PSPS is activated, but maintains grid in sufficiently low risk condition to not require any PSPS activity, though may de-



arny, aroagii maj

ii A partially automated avatam which

F.IV.b Which of the following does the utility take into account when making PSPS decisions? Select all that apply

	recommends circuits for which PSPS should be activated and is validated by
i. SME opinion	SMEs
	i. SME opinion

F.IV.c Under which circumstances does the utility de-energize circuits? Select all that apply.

	i. Upon detection of damaged conditions of electric equipment	ii. When circuit presents a safety risk to suppression or other personnel	iii. When equipment has come into contact with foreign objects posing ignition risk	iv. Additional reasons not listed
Current Year	•		·	
by Start of 2023				

F.IV.d Given the condition of the grid, with what probability does the utility expect any large scale PSPS events affecting more than 10,000 people to occur in the coming year?

<u>Clarification</u>: For the 'Current Year' response option, please take "the coming year" as 2021. For the 'by Start of 2023' response option, please take "the coming year" as 2023.



F.V.a Is there a process for inspecting de-energized sections of the grid

Capability 31

prior to re- energization?



F.V.b How automated is the process for inspecting de-energized sections of the grid prior to re-energization?

<u>Clarification</u>: For explanation on level of automation please refer to the 'level of systematization and automation' in Table 2 of the Maturity Model. (i) in this case corresponds to level 0; (ii) corresponds to level 1 or 2; (iii) corresponds to level 3; and (iv) corresponds to level 4



F.V.c What is the average amount of time that it takes you to re-energize your grid from a PSPS once weather has subsided to below your deenergization threshold?

	i. Longer than 24 hours	ii. Within 24 hours	iii. Within 18 hours	iv. Within 12 hours	v. Within 8 hours
Current Year	0	0	· O		· O
by Start of 2023	· • • •	· O	· O		· O

F.V.d What level of understanding of probability of ignitions after PSPS events does the utility have across the grid?



F.VI Ignition prevention and suppression *Capability 32*

F.VI.a. Does the utility have defined policies around the role of workers in

suppressing ignitions?



F.VI.b What training and tools are provided to workers in the field?

	i. Crews are untrained	ii. Training and communications tools are provided to immediately report ignitions caused by workers or in immediate vicinity of workers	 iii. All criteria in option (ii) met; In addition, suppression tools and training to suppress small ignitions caused by workers or in immediate vicinity of workers are provided 	iv. All criteria in option (iii) met; In addition, communication tools function without cell reception and training by suppression professionals is provided	v. All criteria in option (iv) met and apply to contractors as well as utility workers
Current Year	0	• • •	0	0	
by Start of 2023	· O	• •	0	• O	

F.VI.c In the events where workers have encountered an ignition, have any Cal/OSHA reported injuries or fatalities occurred in in the last year?

<u>Clarification</u>: For this year, please identify whether any major injuries or fatalities have occurred in 2020. For three years from now, please specify whether you think there is a chance that major injuries or fatalities could occur in 2023.

	i. No		ii. Yes
Current Year			0
by Start of 2023		•	0

F.VI.d Does the utility provide training to other workers at other utilities and outside the utility industry on best practices to minimize, report and suppress ignitions?

<u>Clarification</u>: An example of workers outside utility industry might be workers at a vegetation management company who prune trees near utility equipment



G. Data governance

G.I Data collection and curation *Capability* 33

G.I.a Does the utility have a centralized database of situational, operational, and risk data?

<u>Clarification</u>: Question is asking whether utility centralizes most of its situational, operational, and risk data in a single database

	i. No		ii. Yes
Current Year		*	0
by Start of 2023	0	.40	

G.I.b Is the utility able to use advanced analytics on its centralized database of situational, operational, and risk data to make operational and investment decisions?

<u>Clarification</u>: In this case, advanced analytics refers to analysis integrating different types of data from this centralized database in a sufficiently reliable way to create a detailed, quantitative and holistic picture of tradeoffs to be weighed in operational or investment decisions

	i. No	ii. Yes, but only for short term decision making	iii. Yes, for both short term and long-term decision making
Current Year		· O	• O
by Start of 2023	0	• O	

G.I.c Does the utility collect data from all sensored portions of electric lines, equipment, weather stations, etc.?

		i. No		ii. Yes
Current Year	÷	0	*	
by Start of 2023		0		

G.I.d Is the utility's database of situational, operational, and risk data able to ingest and share data using real-time API protocols with a wide variety of stakeholders?

		i. No		ii. Yes
Current Year			ar i	0
by Start of 2023	,			0

G.I.e Does the utility identify highest priority additional data sources to improve decision making?

				iii. Yes, with plans to incorporate these into centralized database of situational, operational
		i. No	ii. Yes	and risk data
Current Year	÷	0		· O
by Start of 2023		0	0	

G.I.f Does the utility share best practices for database management and use with other utilities in California and beyond?

				iii pr	. Yes, with specific ocesses to do so in
	i. No		ii. Yes		place
Current Year		•	0		0
by Start of 2023	0				0

G.II Data transparency and analytics *Capability 34*

G.II.a Is there a single document cataloguing all fire-related data and algorithms, analyses, and data processes?

		i. No		ii. Yes
Current Year				0
by Start of 2023	ğ	0	*	

G.II.b Is there an explanation of the sources, cleaning processes, and assumptions made in the single document catalog?

	i. No		ii. Yes
Current Year		*	0
by Start of 2023	0		

G.II.c Are all analyses, algorithms, and data processing explained and documented? Is there a system for sharing data in real time across multiple levels of permissions?

i. Analyses,

and explained, iii. Analyses, including algorithms and sensitivities for

iv. Analyses, algorithms, and data processing are documented

	data	ii. Analyses, algorithms, and	data processing	eackneypeeof
	processing are	data	are documented	alagnarity siss a andd
	not documented	processing are documented	and explained	data p data essing
Current Year	• •		• O	are documented and explained,
by Start of 2023	i. Analyses, algorithms, and	0	iii. Analyses, algorithms, and	incl o ding sensitivities for

G.II.d Is there a system for sharing data in real time across multiple levels of permissions?

			III. System is capable of
		ii. System is capable of	sharing across at least
		sharing across at least two	three levels of
		levels of permissions,	permissions, including a.)
	 No system capable of 	including a.) utility-	utility- regulator
	sharing data in real time	regulator permissions, and	permissions, b.) first
	across multiple levels of	b.) first responder	responder permissions,
	permissions	permissions	and c.) public data sharing
Current Year	· O	· O	
by Start of 2023	· • • • • • • • • • • • • • • • • • • •	· O	

G.II.e Are the most relevant wildfire related data algorithms disclosed?

<u>Clarification</u>: Question is asking whether <u>all</u> algorithms or decision making process used to inform decision making around investment choices, risk mitigation choices, and emergency response are disclosed



G.III Near-miss tracking

Capability 35

G.III.a Does the utility track near miss data for all near misses with wildfire ignition potential?

<u>Clarification</u>: Recall that near miss is defined as an event with significant probability of ignition, including wires down, contacts with objects, line slap, events with evidence of significant heat generation, and other events that cause sparking or have the potential to cause ignition.

Current Year by Start of 2023

i.	No
(0
(0

ii. Yes

G.III.b Based on near miss data captured, is the utility able to simulate wildfire potential given an ignition based on event characteristics, fuel loads, and moisture?

	i. No		ii. Yes
Current Year	0	×	
by Start of 2023	0		

G.III.c Does the utility capture data related to the specific mode of failure when capturing near- miss data?

	i. No		ii. Yes
Current Year	0	×	
by Start of 2023	0	*	

G.III.d Is the utility able to predict the probability of a near miss in causing an ignition based on a set of event characteristics?

		i. No		ii. Yes
Current Year	,			0
by Start of 2023		0	4	

G.III.e Does the utility use data from near misses to change grid operation protocols in real time?

	i. No		ii. Yes
Current Year		*	0
by Start of 2023		μ0	0

G.IV Data sharing with the research community *Capability 36*

G.IV.a Does the utility make disclosures and share data?

Clarification: In this case, 'disclosures' refer to disclosures to the CPUC and to the public



G.IV.b Does the utility in engage in research?

Clarification: Here, 'research' broadly refers to collaborative research (e.g. with other

available outside parties (such as academics, other utilities, the government or the public).



by Start of 2023	0		0
G.IV.d Does the utili	ity promote best p	practices based on	latest independent

scientific and operational research?

Current Year

.

<u>Clarification</u>: Promoting best practices could take various forms – for example, writing and publicly releasing a report or detailing results achieved when a new method of tool was piloted, including which techniques were more or less effective

		i. No	ii. Yes
Current Year	Ř	0	
by Start of 2023		0	

Ο

H. Resource allocation methodology

H.I Scenario analysis across different risk levels Capability 37

H.I.a For what risk scenarios is the utility able to provide projected cost and total risk reduction potential?

i. Utility does not project proposed initiatives or

ii. Utility provides an accurate high- risk reduction and low risk reduction scenario, and iii. Utility provides an accurate high- risk reduction and low risk reduction scenario, in addition to their proposed scenario, and the

Ο

	costs across different levels of risk scenarios	the projected cost and total risk reduction potential	projected cost and total -iii. Utility provides an risk reduction potential accurate high- risk
Current Year		ii. Utility 😰vides an	reduction and low risk
by Start of 2023	i. Utility door not project proposed initiatives or	reduction and low risk reduction scenario and	addition to their proposed scenario, and the

H.I.b For what level of granularity is the utility able to provide projections for each scenario?

	i. Territory- level or greater	ii. Region level	iii. Circuit level	iv. Span level	v. Asset level
Current Year		0	0	0	· O
by Start of 2023	0	• O	· 🔴	• O	· O

H.I.c Does the utility include a long term (e.g., 6-10 year) risk estimate taking into account macro factors (climate change, etc.) as well as planned risk reduction initiatives in its scenarios?

	i. No		ii. Yes
Current Year	0	·	
by Start of 2023	0	*	

H.I.d Does the utility provide an estimate of impact on reliability factors in its scenarios?

<u>Clarification</u>: Reliability factors here refer to factors impacting reliability of service to customers

	i. No	ii. Yes
Current Year		0
by Start of 2023	0	

H.II Presentation of relative risk spend efficiency for portfolio of initiatives

Capability 38

H.II.a Does the utility present accurate qualitative rankings for its initiatives by risk spend efficiency?

		i. No	ii. Yes
Current Year	,	0	
by Start of 2023	ž	0	

H.II.b What initiatives are captured in the ranking of risk spend efficiency?

i. Common commercial

ii. All commercial

iii. All commercial initiatives and

iv. None of the



H.II.c Does the utility include figures for present value cost and project risk reduction impact of each initiative, clearly documenting all assumptions (e.g. useful life, discount rate, etc.)?

	i. No	ii. Yes
Current Year		0
by Start of 2023	0	

H.II.d Does the utility provide an explanation of their investment in each particular initiative?

Clarification: Reliability factors here refer to factors impacting reliability of service to customers

	i. No		ii. Yes, including the expected overall reduction in risk	iii. Yes, including the expected overall reduction in risk and estimates of impact on reliability factors
Current Year	0	**		· O
by Start of 2023	0		0	

H.II.e At what level of granularity is the utility able to provide risk efficiency figures?

	i. Territory- level or greater	ii. Region level	iii. Circuit level	iv. Span level	v. Asset level
Current Year	0	0		• O	· O
by Start of 2023	· O	0	· •	0	0

H.III Process for determining risk spend efficiency of vegetation management initiatives

Capability 39

H.III.a How accurate of a risk spend efficiency calculation can the utility provide?

i. Utility has no iv. Utility has clear ii. Utility has an iii. Utility has accurate understanding of accurate relative quantitative accurate the relative risk understanding of quantitative understanding of understanding of spend efficiency of the cost and cost, including various clearances effectiveness cost and sensitivities and and types of to produce a effectiveness to effectiveness to vegetation reliable risk spend produce a reliable produce a reliable efficiency management risk spend risk spend initiatives estimate efficiency estimate efficiency estimate

Current Year	⁺i. Utilit ⊘ nas no	· •	0	iv. U🍿y has
by Start of 2023	clear understanding of the relative risk	ii. Utility has an accurate relative understanding of	iii. Utility has accurate quantitative	accurate quantitative understanding of

H.III.b At what level can estimates be prepared?

	i. Less granular than regional, or not at all	ii. Regional	iii. Circuit- based	iv. Span-based	v. Asset-based
Current Year	. 0	· O		• •	· O
by Start of 2023	· O	0		• O	0

H.III.c How frequently are estimates updated?

		i. Never	ii. Less frequently than annually		iii. Annually or more frequently
Current Year		0	0	•	
by Start of 2023	*	0	0	•	

H.III.d What vegetation management initiatives does the utility include within its evaluation?

		i. None	ii. Some	iii. Most	iv. All	sı ir	v. All, upported by ndependent testing
Current Year		0	· O		0		0
by Start of 2023	¥	0	. 0	0		·	0

H.III.e Can the utility evaluate risk reduction synergies from combination of various initiatives?

		i. No		ii. Yes
Current Year	,			0
by Start of 2023	,	0	42	

H.IV Process for determining risk spend efficiency of system hardening initiatives

Capability 40

H.IV.a How accurate of a risk spend efficiency calculation can the utility provide?

i. Utility has no clear understanding of

ii. Utility has an accurate **relative understanding** of the cost and effectiveness to **produce a** iii. Utility has accurate **quantitative** understanding of cost and effectiveness to iv. Utility has accurate quantitative understanding of cost, **including sensitivities** and effectiveness to

	the relative risk spend efficiency of hardening initiatives	reliable risk spend ii. efficience/an accusatimetative	produce a reliable ii r.istrispend s effici enceyicattimate	produ ce ilatychiasble risocomened efficienanyitestionate
Current Year	i. Utility has no	• understanding of the cost and	quantitative understanding of	 understanding of cost. including
by Start of 2023	cear understanding of	effect v eness to produce a	cost and effectiveness to	sensitivities and effectiveness to

H.IV.b At what level can estimates be prepared?

	i. Less granular than regional, or not at all	ii Regional	iii. Circuit-	iv Span-based	v Asset-based
	or not at an	n. rtegionai	bused	IV. Opull bused	v. / 18861 Buseu
Current Year	· O ·	0		• •	· O
by Start of 2023	· O ·	0		0	0

H.IV.c How frequently are estimates updated?

	i. Never	ii. Less frequently than annually		iii. Annually or more frequently
Current Year	0	0		
by Start of 2023	0	0	÷	

H.IV.d What grid hardening initiatives are included in the utility risk spend efficiency analysis?

		i. None	co av	ii. Some mmercially ailable grid nardening initiatives	iii. Mo commere available harden initiativ	est cially e grid ling /es	iv. / comme availab harde initiat	All rcially le grid ning ives	com avai ha initia well initia are l	v. All mercially lable grid rdening atives, as as those tives that ab tested
Current Year	,	0			· O		C)		0
by Start of 2023	2	0	·	0	· O					0

H.IV.e Can the utility evaluate risk reduction effects from the combination of various initiatives?

	i. No		ii. Yes
Current Year		*	0
by Start of 2023	0	*	

H.V Portfolio-wide initiative allocation methodology *Capability 41*

H.V.a To what extent does the utility allocate capital to initiatives based on risk-spend efficiency (RSE)?



H.V.b What information does the utility take into account when generating RSE estimates?



H.V.d Does the utility take into consideration impact on safety, reliability, and other priorities when making spending decisions?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

H.VI Portfolio-wide innovation in new wildfire initiatives

Capability 42

H.VI.a How does the utility develop and evaluate the efficacy of new wildfire initiatives?



H.VI.b How does the utility develop and evaluate the risk spend efficiency of new wildfire initiatives?

<u>Clarification</u>: TCO is total cost of ownership over the expected useful life of an asset, including purchase, operation and maintenance. In this question, total cost of ownership refers to the spend portion of the evaluation of risk spend efficiency, while risk reduction is evaluated separately.

		i. No program in place	i	. Utility uses total cost of ownership
Current Year	,			0
by Start of 2023				0

H.VI.c At what level of granularity does the utility measure the efficacy of new wildfire initiatives?

		i. None		ii. Entire territory	iii. Circuit		iv. Span	v. Asset
Current Year	,	0	-		0	э	0	0
by Start of 2023	-	0	-	0		6	0	0

H.VI.d Are the reviews of innovative initiatives audited by independent parties?

<u>Clarification</u>: Reviews here refer to findings evaluating innovative initiatives which would assist another utility in making a decision about whether to implement that initiative and help them determine how to do so effectively. Criteria might include but are not limited to the following: technical feasibility, effectiveness, risk spend efficiency, ease of implementation and comparison to alternative options

		i. None		ii. Yes
Current Year	,			0
by Start of 2023			-	0

H.VI.e Does the utility share the findings of its evaluation of innovative initiatives with other utilities, academia, and the general public?

		i. None	ii. Yes
Current Year	,	0	
by Start of 2023	,	0	

I. Emergency planning and preparedness

I.I Wildfire plan integrated with overall disaster/ emergency plan

Capability 43

I.I.a Is the wildfire plan integrated with overall disaster and emergency plans?

<u>Clarification</u>: If the utility's wildfire mitigation plan is an integrated component of an overall disaster and emergency plan then the overall plan considers at least the compound effects of risks in both directions – for example, the additional risk of fire posed by an earthquake and how to manage any compounding effects

		ii. Wildfire p component	olan is a of overall	iii. Wildfire plan is an integrated component of overall
	i. No	plan		plan
Current Year	0	. 0		
by Start of 2023	0	· O		

I.I.b Does the utility run drills to audit the viability and execution of its wildfire plans?

	i. No	ii. Yes
Current Year		0
by Start of 2023	0	

I.I.c Is the impact of confounding events or multiple simultaneous disasters considered in the planning process?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

I.I.d Is the plan integrated with disaster and emergency preparedness plans of other relevant stakeholders (e.g., CAL FIRE, Fire Safe Councils, etc.)?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

I.I.e Does the utility take a leading role in planning, coordinating, and integrating plans across stakeholders?

	i. No	ii. Yes
Current Year		0
by Start of 2023	0	

I.II Plan to restore service after wildfire related outage Capability 44

I.II.a Are there detailed and actionable procedures in place to restore service after a wildfire related outage?

	i. No		ii. Yes
Current Year	0		
by Start of 2023	0	*	

I.II.b Are employee and subcontractor crews trained in, and aware of, plans?

		i. No		ii. Yes
Current Year	ĩ	0	×	
by Start of 2023	-	0		

I.II.c To what level are procedures to restore service after a wildfirerelated outage customized?

	i. Territory- wide	ii. R	egion level	iii. Cire	cuit level	iv. S	pan level	v. /	Asset level
Current Year	0	-	0		0	2	0		
by Start of 2023	0		0		0	9	0		

I.II.d Is the customized procedure to restore service based on topography, vegetation, and community needs?

	i. No		ii. Yes
Current Year	0	*	
by Start of 2023	0		

I.II.e Is there an inventory of high risk spend efficiency resources available for repairs?

<u>Clarification</u>: Question is asking whether the resources, components and tools that the utility has available for repairs, maintenance, and unexpected replacement are the most risk spend efficient options on the market



I.III Emergency community engagement during and after wildfire

Capability 45

I.III.a Does the utility provide clear and substantially complete communication of available information relevant to affected customers?

<u>Clarification</u>: Does the utility provide all available information which could be relevant to affected customers in a way that customers can receive in real time and easily understand?

		i. No	ii. Yes	iii r	. Yes, along with eferrals to other agencies
Current Year		0	0	¢.	
by Start of 2023	2	0	0		

I.III.b What percent of affected customers receive complete details of available information?

	i. ≤95% of customers	ii. >95% of customers	iii. >98% of customers	iv. >99% of customers	v. >99.9% of customers
Current Year	· O	0		· O	· O
by Start of 2023	· O	0	· O		· O

I.III.c What percent of affected medical baseline customers receive complete details of available information?

	i. ≤99% of medical baseline customers	ii. >99% of medical baseline customers	iii. >99.5% of medical baseline customers	iv. >99.9% of medical baseline customers	v. 100% of medical baseline customers
Current Year	· O	O		• • •	0
by Start of 2023	· O	0		0	0

I.III.d How does the utility assist where helpful with communication of information related to power outages to customers?

i. Through availability of relevant evacuation information and links on website and toll-free telephone number ii. Through availability of relevant evacuation information and links on website and toll-free telephone number, and assisting disaster response professionals as requested

iii. None of the above

Current Year	0	ii. Through availability of relevant evacuation		0
by Start of 2023	i. Through availability of	information and links on website and toll-free	,	0

I.III.e How does the utility engage with other emergency management agencies during emergency situations?

	i. Utility does not engage with other agencies	ii. Utility engages with other agencies in an ad hoc manner	with emergency management organizations
Current Year	• O		• O
by Start of 2023	· O	· O	

iii. Utility has detailed and

I.III.f Does the utility communicate and coordinate resources to communities during emergencies (e.g., shelters, supplies, transportation etc.)?

		i. No		ii. Yes
Current Year	*	0		
by Start of 2023		0	ii.	

I.IV Protocols in place to learn from wildfire events Capability 46

I.IV.a Is there a protocol in place to record the outcome of emergency events and to clearly and actionably document learnings and potential process improvements?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

I.IV.b Is there a defined process and staff responsible for incorporating learnings into emergency plan?

		i. No	ii. Yes
Current Year		0	
by Start of 2023	8	0	

I.IV.c Once updated based on learnings and improvements, is the updated plan tested using "dry runs" to confirm its effectiveness?

i. No	ii. Yes
-	

Current Year by Start of 2023



ii. Yes

I.IV.d Is there a defined process to solicit input from a variety of other stakeholders and incorporate learnings from other stakeholders into the emergency plan?

	i. No		ii. Yes
Current Year	0		
by Start of 2023	0	ж.	

i. No

0

I.V Processes for continuous improvement after wildfire and PSPS events

Capability 47

I.V.a Does the utility conduct an evaluation or debrief process after a wildfire?

		i. No	ii. Yes
Current Year		0	
by Start of 2023	8	0	

I.V.b Does the utility conduct a customer survey and utilize partners to disseminate requests for stakeholder engagement?

	i. No	ii. One or the other	iii. Both
Current Year	0	. O	
by Start of 2023	0	· • • • • •	

I.V.c In what other activities does the utility engage?

	i. None	ii. Public listening sessions	iii. Debriefs with partners	iv. Public listening sessions, debriefs with partners, and others
Current Year	0	0	. O	
by Start of 2023	0	0	0	

I.V.d Does the utility share with partners findings about what can be improved?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

I.V.e Are feedback and recommendations on potential improvements made public?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

I.V.f Does the utility conduct proactive outreach to local agencies and organizations to solicit additional feedback on what can be improved?

		i. No		ii. Yes
Current Year	·	0	×	
by Start of 2023		0	. #1	

I.V.g Does the utility have a clear plan for post-event listening and incorporating lessons learned from all stakeholders?

	i. No		ii. Yes
Current Year	0		
by Start of 2023	0	-	

I.V.h Does the utility track the implementation of recommendations and report upon their impact?

<u>Clarification</u>: Recommendations here refer to recommendations from customers, local agencies, organizations and other stakeholders received following a wildfire or PSPS event

		i. No		ii. Yes
Current Year	3		*	0
by Start of 2023		0		

I.V.i Does the utility have a process to conduct reviews after wildfires in other the territory of other utilities and states to identify and address areas of improvement?

		i. No		ii. Yes
Current Year		0	-	
by Start of 2023	3	0		

J. Stakeholder cooperation and community engagement

J.I Cooperation and best practice sharing with other

Capability 48

J.I.a Does the utility actively work to identify best practices from other utilities through a clearly defined operational process?

		i No	II. Yes, from other	11. Y	es, from other global	
		1. INO	Camornia utilities		utilities	
Current Year	÷	0	0			
by Start of 2023		0	0			

J.I.b Does the utility successfully adopt and implement best practices identified from other utilities?

	i. No		ii. Yes
Current Year	0		
by Start of 2023	0	w.	

J.I.c Does the utility seek to share best practices and lessons learned in a consistent format?

	i. No		ii. Yes
Current Year	0	*	
by Start of 2023	0	*	

J.I.d Does the utility share best practices and lessons via a consistent and predictable set of venues/media?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

J.I.e Does the utility participate in annual benchmarking exercises with other utilities to find areas for improvement?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

J.I.f Has the utility implemented a defined process for testing lessons learned from other utilities to ensure local applicability?



J.II Engagement with communities on utility wildfire mitigation initiatives

Capability 49

J.II.a Does the utility have a clear and actionable plan to develop or maintain a collaborative relationship with local communities?

	i. No		ii. Yes
Current Year	0	*	
by Start of 2023	0	А.	

J.II.b Are there communities in HFTD areas where meaningful resistance is expected in response to efforts to mitigate fire risk (e.g. vegetation clearance)?

	i. No		ii. Yes
Current Year	0	κ.	
by Start of 2023	0	Ϋ́.	

J.II.c What percent of landowners are non-compliant with utility initiatives (e.g., vegetation management)?

	i. More 5%	than	ii. Less tha 5%	in iii.	Less tha 2%	n iv.	Less tha 1%	n	v. Less than 0.5%
Current Year	. 0		0		0		0	x	
by Start of 2023	· 0		0		0	,	0		

J.II.d What percent of landowners complain about utility initiatives (e.g., vegetation management)?

	i. More than 5%	ii. Less than 5%	iii. Less than 2%	iv. Less than 1%	v. Less than 0.5%
Current Year	· O	• O	· O		· O
by Start of 2023	0	0	0		. 0

J.II.e Does the utility have a demonstratively cooperative relationship with communities containing >90% of the population in HFTD areas (e.g. by being recognized by other agencies as having a cooperative relationship with those communities in HFTD areas)?

Current Year by Start of 2023

Ì.	Ĵ	Ν	lc)
	(

ii. Yes

J.II.f Does utility have records of landowners throughout communities containing >90% of the population in HFTD areas reaching out to notify of risks, dangers or issues in the past year?

<u>Clarification</u>: For this year, please identify whether the question holds true for 2020. For three years from now, specify whether you expect the question to hold true in 2023.

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

J.III Engagement with LEP and AFN populations Capability 50

J.III.a Can the utility provide a plan to partner with organizations representing Limited English Proficiency (LEP) and Access & Functional Needs (AFN) communities?

	i. No		ii. Yes
Current Year	0	•	
by Start of 2023	0	-	

J.III.b Can the utility outline how these partnerships create pathways for implementing suggested activities to address the needs of these communities?

		i. N o	ii. Yes
Current Year		0	
by Start of 2023	,	0	

J.III.c Can the utility point to clear examples of how those relationships have driven the utility's ability to interact with and prepare LEP & AFN communities for wildfire mitigation activities?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

J.III.d Does the utility have a specific annually-updated action plan further reduce wildfire and PSPS risk to LEP & AFN communities?

		i. No	ii. Yes
Current Year		0	
by Start of 2023	*	0	





iii. Utility cooperates with

J.IV. Collaboration with emergency response agencies

Capability 51

J.IV.a What is the cooperative model between the utility and suppression agencies?

	i. Utility does not sufficiently cooperate with suppression agencies	ii. Utility cooperates with suppression agencies by notifying them of ignitions	working cooperatively with them to detect ignitions, in addition to notifying them of ignitions as needed
Current Year	· O	· • • • • • • • • • • • • • • • • • • •	
by Start of 2023	· O	• O	

J.IV.b In what areas is the utility cooperating with suppression agencies

	i. High risk areas	ii. All areas under utility control	iii. Throughout utility service areas	iv. None of the above
Current Year	· O	· O		0
by Start of 2023	· O	O		0

J.IV.c Does the utility accurately predict and communicate the forecasted fire propagation path using available analytics resources and weather data?

		i. No	ii. Yes
Current Year	;		0
by Start of 2023		0	

J.IV.d Does the utility communicate fire paths to the community as requested?

	i. No	ii. Yes
Current Year		0
by Start of 2023		0

J.IV.e Does the utility work to assist suppression crews logistically, where possible?

	i. No	ii. Yes
Current Year	0	
by Start of 2023	0	

J.V. Collaboration on wildfire mitigation planning with stakeholders

Capability 52

J.V.a Where does the utility conduct substantial fuel management?

	i. Utility does not conduct fuel management	ii. Utility conducts fuel management along rights of way	iii. Utility conducts fuel management throughout service area
Current Year		• O	0
by Start of 2023		0	0

J.V.b Does the utility engage with other stakeholders as part of its fuel management efforts?

				iv. Utility shares fuel	v. Utility shares
				management plans with	management plans with
				stakeholders, and	stakeholders, and pro-
				coordinates	actively
				Tuei management	coordinates fuel
				activities, including	management activities,
			iii. Utility shares fuel	adjusting plans, to	including adjusting
			management	cooperate with other	plans, to
			other	stakeholders	other
	i. Utility does not	ii Lifilifiz	stakeholders and works with other	state-wide to focus on	stakeholders state-wide to
	with broader fuel management efforts by other stakeholders	shares fuel management plans with other stakeholders	stakeholders conducting fuel management concurrently	would have the biggest impact in reducing wildfire risk	that would have the biggest impact in reducing wildfire risk
Current Year		0	· 0	• O	0
by Start of 2023	0	0	· •	0	· O

J.V.c Does the utility cultivate a native vegetative ecosystem across territory that is consistent with lower fire risk?

	i. No	ii. Yes
Current Year		0
by Start of 2023		0

J.V.d Does the utility fund local groups (e.g., fire safe councils) to support fuel management?

	i. No		ii. Yes
Current Year	0	a:	
by Start of 2023	0	ж.	

J.V.e Do you have any additional comments?

Powered by Qualtrics ⊡

Verification for the Utility Wildfire Mitigation Maturity Survey

Utilities shall complete the following verification, attached to a PDF of their electronic survey responses, following completion of the electronic survey. This document will be shared with the utilities for completion within one business day of completing the electronic survey.

Complete the following verification for the Utility Wildfire Mitigation Maturity Survey submission:

(See Rule 1.11) (Where Applicant is a Corporation)

I am an officer of the applicant corporation herein, and am authorized to make this verification on its behalf. The responses in the attached survey are true of my own knowledge.

I declare that the foregoing is true and correct.

Executed on _	2/8/2021	at	Alamo	, California.	
	(Date)		(Name of city)		
Dublin Powell					

(Signature and Title of Corporate Officer)