

State of California
Office of Energy Infrastructure Safety

TEXT OF REGULATIONS

TITLE 14. NATURAL RESOURCES

DIVISION 17. OFFICE OF ENERGY INFRASTRUCTURE SAFETY

CHAPTER 2. INVESTIGATION AND COMPLIANCE

ARTICLE 1. REPORTING, INVESTIGATION, VIOLATIONS

The text originally proposed to be adopted and published for the 45-day period appears in underline. The modifications proposed to be added, and which are published for the 15-day period, appear in double underline and ~~double-strikeout~~.

§ 29300. Notifications

- (a) A regulated entity must notify the Office within one business day after the regulated entity knows, or has reason to know of observing, with respect to a fire requiring a response from a fire suppression agency, when:
- (1) A fault, outage, or other anomaly has occurred on infrastructure that it owns or operates within six hours of the start of the fire; and
 - (2) The infrastructure with the fault, outage, or anomaly is within one mile of either the origin of the fire or perimeter of the fire at the time of the notification, whichever is known and closest.
- (b) A regulated entity must notify the Office within four hours after the regulated entity knows, or has reason to know, receiving notice that either: (1) infrastructure owned or operated by the regulated entity might have caused a fire requiring a response from a fire suppression agency, or (2) a government entity is

investigating whether infrastructure owned or operated by the regulated entity caused a fire.

(c) For purpose of this section, “anomaly” is defined to mean an unplanned condition outside of normal operating parameters of a power grid that does not result in a fault or an outage.

~~(d) For purpose of this section, “start of the fire” is defined to mean when a regulated entity knows, or has reason to know, of the fire.~~

Note: Authority cited: Sections 15473 and 15475, Government Code.
Reference: Section 15473 and 15475, Government Code.